

EC type examination certificate
EG-Baumusterprüfbescheinigung

CE-0085CQ0238

Product Identification No.
 Produkt-Identnummer

Field of Application <i>Anwendungsbereich</i>	EC Gas Appliances Directive (2009/142/EC) <i>EG-Gasgeräterichtlinie (2009/142/EG)</i>
Owner of Certificate <i>Zertifikatinhaber</i>	Bosch Thermotechnik GmbH Sophienstraße 30-32, D-35576 Wetzlar
Distributor <i>Vertreiber</i>	Bosch Thermotechnik GmbH Sophienstraße 30-32, D-35576 Wetzlar
Product Category <i>Produktart</i>	Boilers with flue systems: Condensing combi water heater (3204)
Product Description <i>Produktbezeichnung</i>	condensing combi water heater optional also as water heater for central heating
Model <i>Modell</i>	Logamax Plus GB172-...i
Countries of Destination <i>Bestimmungsländer</i>	AT, BE, BY, DE, EE, GR, HU, IT, KZ, LT, LU, LV, RO, RU, TR, UA
Test Reports <i>Prüfberichte</i>	type testing: B15/07/1992EU from 28.07.2015 (DBI)
Test Basis <i>Prüfgrundlagen</i>	EU/2009/142/EG (30.11.2009) DIN EN 15502-1 (01.10.2012) DIN EN 15502-2/1 (01.01.2013) DIN EN 13203-1 (draft 01.06.2015)

File Number 15-0412-GEE
Aktenzeichen

21.09.2015 Rie A-1/2

Date, Issued by, Signer, Head of Certification Body
 Datum, Bearbeiter, Blatt, Leiter der Zertifizierungsstelle

DVGW CERT GmbH is an accredited body by DAkkS according to DIN EN ISO/IEC 17065:2013 and notified by the government of the Federal Republic of Germany for certification of gas appliances under EC Directive

DVGW CERT GmbH ist von der DAkkS nach DIN EN ISO/IEC 17065:2013 akkreditierte und von der Deutschen Bundesregierung benannte Stelle für die Zertifizierung von Gasgeräten gemäß EG-Richtlinie 2009/142/EG.



Deutsche
 Akkreditierungsstelle
 D-ZE-16028-01-01

DVGW CERT GmbH
 Zertifizierungsstelle

Josef-Wirmer-Str. 1-3
 53123 Bonn

Tel. +49 228 91 88 - 888
 Fax +49 228 91 88 - 993

www.dvgw-cert.com
 info@dvgw-cert.com

Elektrical Data 230 V AC, 50 Hz
Elektrische Daten

Appliance Categories <i>Gerätekatégorien</i>	Supply Pressures <i>Versorgungsdrücke</i>	Countries of Destination <i>Bestimmungsländer</i>	Remarks <i>Bemerkungen</i>
I2E(S)	20/25 mbar	BE	
I3P	37 mbar	BE	
I12E3B/P	20, 28-30 mbar	LU	
I12ELL3B/P	20, 50 mbar	DE	
I12H3B/P	20, 28-30 mbar	IT, TR	
I12H3B/P	20, 30 mbar	EE, LT, LV, RO	
I12H3B/P	20, 37 mbar	GR	
I12H3B/P	20, 50 mbar	AT	
I12HS3B/P	25, 30 mbar	HU	

Type <i>Typ</i>	Technical Data <i>Technische Daten</i>	Remarks <i>Bemerkungen</i>
GB172-30 iK...	nominal heat output: 3,8...28,1 kW heat input (Hi): 3,9...28,7 kW	
GB172-35 i(K)	nominal heat output: 5,0...33,0 kW heat input (Hi): 5,2...33,8 kW	
GB172-42 i	nominal heat output: 5,3...39,9 kW heat input (Hi): 5,5...41,0 kW	

Hints of Utilization /Remarks

Verwendungshinweise / Bemerkungen

flue types B23, B33, C13(x), C33(x), C43(x), C53(x), C63(x), C83(x) and C93(x): according to installation manual "Logamax Plus GB172..."

Additional proved countries of destination, appliance categories and supply pressures:

UA: I12H3B/P (13, 28-30 mbar)

BY, KZ, RU: I12H3B/P (13, 30 mbar)

In Belarus, Kazakstan, in the Ukraine and in the Russian Federation the CE-marking will be accepted as conformity approval if the Gas Appliance Directive (2009/142/EC) is transferred into national law by Belarus, Kazakstan, Ukraine and the Russian Federation.